

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI005880A -R2
DATE: 12/10/2004
CERTIFICATION PROGRAM: Structural
COMPANY: Window Crafts.
CODE: W-690-1
REVISION DATE: 02/05/2010

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied. The product described below is approved for listing in the Directory of Certified Products at www.NAMICertification.com. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Window Craftsman 6031 Clark Center Avenue Sarasota, FL 34238	Series "50" Aluminum Flange Impact Frame Horizontal Sliding Window Configuration: XX Glazing: Laminate-3/16" Annealed Glass/0.090"PVB Interlayer by Solutia/ 3/16" Annealed Glass Frame: W-6'0" H-5'3" Panel: W-3'1" H-5'1" STP: Pos+75.0 psf Neg-75.0 psf

SPECIFICATION	PRODUCT RATING
ASTM E1886-02/E1996-02 AAMA/NWWDA 101/LS.2-97 AAMA 1303.5-76	Design Pressure: +50/-50 psf Wind Zone 4-Missile Level D HS-C50 FER-Passed

Product Tested By: Certified Testing Laboratories
 Report No: CTLA-1294W/CTLA-1294W-1
 Expiration Date: October 31, 2012

Administrator's Signature: _____


NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Fax: (804) 684-5122