


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI005907A-R2
DATE: 01/05/2005
CERTIFICATION PROGRAM: Structural
COMPANY: Window Crafts.
CODE: W-690-1
REVISION DATE: 12/19/2008

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at www.NAMICertification.com. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Window Craftsman 6031 Clark Center Avenue Sarasota, FL 34238	Aluminum Prime Entry Outswing Door w/Vertical Sliding Acrylic Window and Opaque Insulated Kick Panel Glazing: 0.125" Acrylic <u>STP PSF</u> Frame: W-3'2" Panel: W-3'0" Pos+21.6 H-6'9" H-5'10" Neg-21.6

SPECIFICATION	PRODUCT RATING
ASTM E330-02/E547-00	Design Pressure: +14.4/-14.4 psf

Product Tested By: Certified Testing Laboratories
Report No: CTLA-1297W
Expiration Date: August 31, 2012

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122