

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI005980A-R3
DATE: 05/26/2007
CERTIFICATION PROGRAM: Structural
COMPANY: Window Crafts.
CODE: W-690-1
REVISION DATE: 02/02/2011

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied. The product described below is approved for listing in the Directory of Certified Products at www.NAMICertification.com. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Window Craftsmen, Inc. 6031 Clark Center Avenue Sarasota, FL 34238	Series "70R Glass Sliding Doors" Pocket/By-Pass/Center Meet Aluminum Sliding Impact Glass Door Configuration: XXXX Glazing-All Panels: 1/4"Heat Strengthened Glass/0.090"PVB/1/4"Heat Strengthened Glass Frame: W-4876mm(192") H-2438mm(96") Panel: W-1283mm(50.5") H-2407mm(94.75") STP: Pos+5400Pa(112.5psf) Neg-5400Pa(112.5 psf)

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05 TAS 201/202/203-94 ASTM E1886-02/E1996-02 ASTM F842-97	SD-C70 4876 x 2438 (192 x 96) Design Pressure: +70/-70 psf Large Missile Impact Rated Wind Zone 4-Missile Level D FER-Passed

Product Tested By: National Certified Testing Laboratories
 Report No: NCTL-210-3220-1D(Structural)/210-3112-1/210-3112-1A (Impact)
 Expiration Date: **February 28, 2015**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124 Fax: (804) 684-5122