


# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI006690-R1  
**DATE:** 08/29/2005  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Window Crafts.  
**CODE:** W-690-1  
**REVISION DATE:** 02/05/2010

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at [www.NAMICertification.com](http://www.NAMICertification.com). Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Window Craftsman</b> <b>6031 Clark Center Avenue</b> <b>Sarasota, FL 34238</b>	<b>Series "50" Aluminum Sliding Pocket/ By-Pass/Center-Meet Glass Door</b>  Configuration: XXXX  Glazing: 1/4" Tempered Glass  Frame: W-4876mm(192") H-2438mm(96")  Panel: W-1283mm(50.5")H-2407mm(90.5")  STP: Pos+3600Pa(75psf) Neg-3600Pa(75psf)

SPECIFICATION	PRODUCT RATING
<b>AAMA/NWWDA 101/I.S.2-97/ AAMA/WDMA/CSA 101/I.S.2/A440-05/ TAS 202-94</b>	<b>SGD-C50 SD-C50 4876 x 2438 (192 x 96) Design Pressure: +50/-50 psf</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3220-1/1B  
Expiration Date: April 30, 2012

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122