

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009413-R2  
DATE: 03/28/2008  
CERTIFICATION PROGRAM: Structural  
COMPANY: Window Crafts.  
CODE: W-690-1  
REVISION DATE: 12/07/2010

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied. The product described below is approved for listing in the Directory of Certified Products at [www.NAMICertification.com](http://www.NAMICertification.com). Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Window Craftsman</b> <b>6031 Clark Center Avenue</b> <b>Sarasota, FL 34238</b>	<b>"60R Aluminum Impact Picture Window"</b>  <b>Aluminum Fixed Window</b>  Configuration: O  Glazing: Laminate-1/4" Heat Strengthened Glass/0.090" PVB by Solutia/1/4" Heat Strengthened Glass  Frame: W-1219mm (48") H-3456mm(72")  Daylight: W-1168mm(46") H-1778mm(70")  STP: Pos+6480Pa(135psf) Neg-6480Pa(135 psf)

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> <b>ASTM E1886-02/E1996-02</b> <b>TAS 201/202/203-94</b> <b>ASTM F588-04</b>	<b>FW-R60 1219 x 3456 (48 x 72)</b> <b>Wind Zone 4-Missile Level D</b> <b>Design Pressure: +60/-60 psf</b> <b>FER-Passed</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3403-1 & 1A  
Expiration Date: November 30, 2014

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122