



SECTION A

GENERAL NOTES:

- 1) ALUMINUM EXTRUSIONS SHALL BE 6063-T5 ALUMINUM ALLOY. FASTENERS SHALL BE 18-8 STAINLESS STEEL.
- 2) INSTALLATION CLIPS, FASTENED INTO ALUMINUM SCREEN INCLOSURE FRAMING OR OTHER FRAMING WITH #8 SCREW, SHALL BE SPACED 6" MAX. FROM EACH CORNER AND SPACED 18" O.C. TYP. MAX.
- 3) FRAMES SHALL BE REMOVED WHEN WINDS APPROACHED 75 MPH. AS PER FLORIDA BUILDING CODE SECTION 2002.3.3

WINDOW CRAFTSMAN  
SARASOTA, FLORIDA

TITLE: LIP FRAME GLASS OR ACRYLIC ELEVATION & INSTALLATION DETAIL			
AREA:	APRVD:	DRN: JVS	DATE: 5/23/05
WT/FT:	SCALE: N.T.S.	MATL:	DWG. NO: WIC0007

PREPARED BY:  
**PTC**  
PTC Engineering, Inc.  
2381 S.E. Seafury Lane  
Port St. Lucie, Florida 34952  
Phone 772.398.4639 Fax 772.398.4654

SYM	REVISION	DATE	BY