



SECTION A

GENERAL NOTES:

- 1) ALUMINUM EXTRUSIONS SHALL BE 6063-T5 ALUMINUM ALLOY.
FASTENERS SHALL BE 18-8 STAINLESS STEEL.
- 2) INSTALLATION CLIPS, FASTENED INTO ALUMINUM SCREEN INCLOSURE FRAMING OR OTHER FRAMING WITH #8 SCREW, SHALL BE SPACED 6" MAX. FROM EACH CORNER AND SPACED 18" O.C. TYP. MAX.
- 3) FRAMES SHALL BE REMOVED WHEN WINDS APPROACHED 75 MPH. AS PER FLORIDA BUILDING CODE SECTION 2002.3.3

SYM	REVISION	DATE	BY

PREPARED BY:

 PTC Engineering, Inc.
 2361 S.E. Seafury Lane
 Port St. Lucie, Florida 34952
 Phone 772.398.4639 Fax 772.398.4654

<h2 style="margin: 0;">WINDOW CRAFTSMAN</h2> <p style="margin: 0;">SARASOTA, FLORIDA</p>			
TITLE: LIP FRAME VINYL ELEVATION & INSTALLATION DETAIL			
AREA:	APRVD:	DRN:	DATE:
		BB	5/23/05
WT/FT:	SCALE:	MATL:	DWG. NO:
	N.T.S.		WIC0006