


# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI005904  
DATE: 12/10/2004  
CERTIFICATION PROGRAM: Structural  
COMPANY: Window Crafts.  
CODE: W-690-1  
REVISION DATE: 10/31/2007

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at [www.NAMICertification.com](http://www.NAMICertification.com). Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Window Craftsman 6031 Clark Center Avenue Sarasota, FL 34238	Aluminum Fin Frame Double Hung Acrylic Wind Breaker Configuration: XX Acrylic: 0.120" Thick STP PSF Frame: W-4'6" Panel: W-3'6" Pos+14.40 H-7'0" H-4'5" Neg-14.40

SPECIFICATION	PRODUCT RATING
ASTM E547-00/E330-99/02	Design Pressure: +9.6/-9.6

Product Tested By: Certified Testing Laboratories  
Report No: CTLA-1179W-1  
Expiration Date: October 31, 2008

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, consisting of several loops and strokes, positioned above a horizontal line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659