


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI005905-R2
DATE: 12/10/04
CERTIFICATION PROGRAM: Structural
COMPANY: Window Crafts.
CODE: W-690-1
REVISION DATE: 07/10/2008

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at www.NAMICertification.com. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Window Craftsman 6031 Clark Center Avenue Sarasota, FL 34238	Aluminum Fin Frame Horizontal Sliding Window Configuration: X/X Glazing: 1/4" Annealed Glass STP PSF Frame: W-6'0" Panel: W-3'1" Pos+60.0 H-6'0" H-5'10" Neg-60.0

SPECIFICATION	PRODUCT RATING
AAMA/NWWDA 101/LS.2-97/ ASTM F588-97	HS-R40 FER-Passed

Product Tested By: Certified Testing Laboratories
Report No: CTLA-1245W
Expiration Date: April 30, 2009

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**

11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659