

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI005905A-R2  
**DATE:** 12/10/04  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Window Crafts.  
**CODE:** W-690-1  
**REVISION DATE:** 07/10/2008

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at [www.NAMICertification.com](http://www.NAMICertification.com). Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Window Craftsman</b> <b>6031 Clark Center Avenue</b> <b>Sarasota, FL 34238</b>	<b>Aluminum Fin Frame Horizontal</b> <b>Sliding Window</b> Configuration: XX IG-1/4" Annealed Glass <p style="text-align: right;"><u>STP PSF</u></p> Frame: W-6'0"   Panel: W-3'1"   Pos+67.5 H-5'3"                      H-5'1"   Neg-67.5

SPECIFICATION	PRODUCT RATING
AAMA/NWWDA 101/LS.2-97/ AAMA 1303.5-76	<b>HS-R45</b> <b>FER-Passed</b>

Product Tested By: Certified Testing Laboratories  
 Report No: CTLA-1245W  
 Expiration Date: April 30, 2009

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND**  
**MANAGEMENT INSTITUTE, INC.**

11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659