


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI005911-R2
DATE: 01/05/2005
CERTIFICATION PROGRAM: Structural
COMPANY: Window Crafts.
CODE: W-690-1
REVISION DATE: 08/29/2007

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at www.NAMICertification.com. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Window Craftsman 6031 Clark Center Avenue Sarasota, FL 34238	Aluminum Fin Frame Impact Rated Fixed Picture Window Configuration: O Glazing: 0.250" Heat Strengthened Glass/ 0.090" PVB/0.250" Heat Strengthened Glass Frame: W-5'2" H-6'2"

SPECIFICATION	PRODUCT RATING
SBCCI/SSTD 12-99 Glass Complies to ASTM E1300-02	Design Pressure: +50/-50 psf Large Missile Impact Rated

Product Tested By: Certified Testing Laboratories
 Report No: CTLA-879W-1-R
 Expiration Date: **September 30, 2008**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**

11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659