


# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI005981-R1  
**DATE:** 04/18/2005  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Window Crafts.  
**CODE:** W-690-1  
**REVISION DATE:** 12/19/2008

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at [www.NAMICertification.com](http://www.NAMICertification.com). Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Window Craftsman</b> 6031 Clark Center Avenue Sarasota, FL 34238	<b>Aluminum 4-Track Horizontal</b> <b>Sliding Acrylic Windbreaker Fin Frame</b> Configuration: XXXX Glazing: 0.125" Acrylic <u>STP PSF</u> Frame: W-12'0" Panel: W-3'1" Pos+14.4 H-8'0" H-7'10" Neg-14.4

SPECIFICATION	PRODUCT RATING
ASTM E330-02	Design Pressure: +9.6/-9.6 psf

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3119-01 (Structural)  
Expiration Date: **February 28, 2011**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659