


# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI006062  
**DATE:** 06/07/2005  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Window Crafts.  
**CODE:** W-690-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at [www.NAMICertification.com](http://www.NAMICertification.com). Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Window Craftsman</b> <b>6031 Clark Center Avenue</b> <b>Sarasota, FL 34238</b>	<b>Series "Aluminum Picture Window"</b> <b>Aluminum Fin Frame Fixed Window</b>  O/CG/.250AnnealedGL/FER  <b>STP PSF</b>  Frame: W-5'0"Opening: W-4'10" Pos+67.5 H-5'0" H-4'10" Neg-67.5

SPECIFICATION	PRODUCT RATING
<b>AAMA/NWWDA 101/I.S.2-97/</b> <b>ASTM F588-97</b>	<b>F-C45</b> <b>FER-Passed</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3160-02 (Structural/FER)  
Expiration Date: **June 30, 2009**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659



June 13,2005

National Accreditation & Management Institute, INC.  
11870 Merchants Walk Suite 202  
Newport News, VA 23606

RE: Window Craftsmen (Certification Program)

Dear Sharon:

This is to confirm that glass listed in the products below for Window Craftsmen have been verified and will comply to the requirements of the 2004 Florida Building Code as per Chapter 24 Section 2404.1 and (Referenced Standards) Chapter 35 Section 35.13.

(See following list of products)

1. 60" x 60" PW (D.P. 45) 1/4" Ann. Glass NCTL-210-3160-02
2. 120" x 60" PW (D.P. 60) 3/16" Tempered Glass NCTL-210-3160-01

Sincerely,

Jim Moore V.P./G.M.  
PTC Engineering, Inc.

PTC Engineering, Inc.  
2361 S.E. Seafury Lane - Port St. Lucie, FL 34952  
Phone: 772-785-5901 Fax: 772-785-5901