


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006716
DATE: 09/18/2006
CERTIFICATION PROGRAM: Structural
COMPANY: Window Crafts.
CODE: W-690-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at www.NAMICertification.com. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Window Craftsman 6031 Clark Center Avenue Sarasota, FL 34238	Series "75" Aluminum Pocket/By-Pass/ Center-Meet Sliding Glass Door Configuration: XXXX Glazing: 1/4" Tempered Glass Frame: W-4876mm(192") H-2438mm(96") Panel: W-1245mm(49") H-2407mm(94.75") STP: Pos5400Pa(112.5psf) Neg-5400Pa(112.5psf)

SPECIFICATION	PRODUCT RATING
AAMA/NWDA 101/I.S.2-97 AAMA/WDMA/CSA 101/I.S.2/A440-05 TAS 202-94 Complies to ASTM E1300-02	SGD-C75 SD-C75 4876mm x 2438mm (192 x 96) Design Pressure: +75/-75 psf

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3220-1A/1B
Expiration Date: April 30, 2010

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659