


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009608
DATE: 09/09/2008
CERTIFICATION PROGRAM: Structural
COMPANY: Window Crafts.
CODE: W-690-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied. The product described below is approved for listing in the Directory of Certified Products at www.NAMICertification.com. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Window Craftsman 6031 Clark Center Avenue Sarasota, FL 34238	Series "Two-Track Horizontal Slider (Windbreak)" Configuration: XX Glazing: 1/8" Annealed Glass Frame: W-2134mm (84") H-2134mm(84") Panel: W-1060mm(41.7") H-1060mm(72.5")

SPECIFICATION	PRODUCT RATING
ASTM E330-02	Design Pressure: +14.4/-14.4 psf

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3545-1
Expiration Date: **July 31, 2012**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659