


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009764
DATE: 01/22/2009
CERTIFICATION PROGRAM: Structural
COMPANY: Window Crafts.
CODE: W-690-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied. The product described below is approved for listing in the Directory of Certified Products at www.NAMICertification.com. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Window Craftsman 6031 Clark Center Avenue Sarasota, FL 34238	Series "Two-Track Horizontal 80 Rated 7/16" Impact Glass Slider" Aluminum Horizontal Sliding Window Configuration: XX Glazing: 1/8" Annealed Glass/0.090" PVB Interlayer by Solutia/1/8" Annealed Glass Frame: W-1829mm(72") H-1829mm(72") Panel: W-914mm(36") H-1772mm(69.75") STP: Pos+5760Pa(120 psf) Neg-5760Pa(120 psf)

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/LS.2/A440-05 ASTM E1886-02/05/E1996-02/05 TAS 201/202/203-94/ ASTM F588-04	HS-C80 1829 x 1829 (72 x 72) Design Pressure: +80/-80 psf Wind Zone 4-Missile Level D Large Missile Impact Rated FER-Passed

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3557-3/NCTL-210-3557-3A
Expiration Date: November 30, 2012

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659