


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009764A
DATE: 01/22/2009
CERTIFICATION PROGRAM: Structural
COMPANY: Window Crafts.
CODE: W-690-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied. The product described below is approved for listing in the Directory of Certified Products at www.NAMICertification.com. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Window Craftsman 6031 Clark Center Avenue Sarasota, FL 34238	Series "Two-Track Horizontal 70 Rated 1/4" Tempered Glass Slider" Aluminum Horizontal Sliding Window Configuration: XX Glazing: 1/4" Tempered Glass Frame: W-1829mm(72") H-1829mm(72") Panel: W-914mm(36") H-1772mm(69.75") STP: Pos+5040Pa(105 psf) Neg-5040Pa(105 psf)

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/LS.2/A440-05 TAS 202-94 ASTM F588-04	HS-C70 1829 x 1829 (72 x 72) FER-Passed

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3557-3/NCTL-210-3557-4
Expiration Date: November 30, 2012

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659