



- NOTES:**
1. THE PRODUCT SHOWN HEREIN IS TO BE INSTALLED ON ENCLOSURE THAT COMPLIES WITH THE 2007 FLORIDA BUILDING CODE WITH 2009 SUPPLEMENT.
 2. ENCLOSURE TO BE DESIGNED AND ANCHORED TO PROPERLY TRANSFER ALL LOADS TO STRUCTURE. ENCLOSURE IS THE RESPONSIBILITY OF THE ARCHITECT OR ENGINEER OF RECORD.
 3. WINDOW VENTS SHALL BE REMOVED WHEN 3 SECOND GUSTS, V3S=75 MPH AS PER SECTION 1622.2.1 OF THE FLORIDA BUILDING CODE. REMOVABLE PANELS SHALL BE IDENTIFIED AS REMOVABLE BY A DECAL. THE IDENTIFICATION DECAL SHALL ESSENTIALLY STATE: "Removable panel shall be removed when wind speeds, exceed 75 mph (34m/s)." DECALS SHALL BE PLACED SUCH THAT THE DECAL IS VISIBLE WHEN THE PANEL IS INSTALLED.
 4. AN APPROVED MEMBRANE OR MATERIAL SHALL BE PLACED BETWEEN ALL DISSIMILAR METALS TO CONTROL GALVANIC CORROSION.
 5. WINDOW FRAME AND VENT MATERIAL SHALL BE ALUMINUM ALLOY 6063-T5.
 6. USE LATEX CAULK TO SEAL BEHIND FLANGES, BETWEEN COMPONENT SEAMS AND FRAME CORNERS. APPLICATION OF LATEX CAULK MUST COMPLY WITH SEALANT MANUFACTURER'S RECOMMENDATIONS.
 7. #10 SMS SCREWS INSTALLATION ANCHORS MUST BE SPACED AS FOLLOW:
 HEAD AND SILL: 6" MAX. FROM CORNERS AND SPACED 18" MAX. O.C.
 SIDE JAMBS : 6" MAX. FROM CORNERS AND SPACED 18" MAX. O.C.
 8. SECTION 1622.1, SCREEN ENCLOSURES FOR HVHZ OF THE 2009 SUPPLEMENTS ALLOW THE USE OF VINYL AND ACRYLIC.

WINDOW CRAFTSMEN, INC.		
SARASOTA, FLORIDA		
TITLE: ACRYLIC PICTURE WINDOW WINDBREAK - INSTALLATION DETAILS, IN ALUMINUM		
ENGINEER: MARK A. SMITH	DRAWN BY: MAS	DATE: 11/20/07
DISCIPLINE: CIVIL	SCALE: N.T.S.	DWG. NO. WCI-PIC-001
FL. REG. NO.: 55511	REV. LETTER: A	SHEET 1 OF 1