



- NOTES:
- 1) WINDOW FRAME MATERIAL SHALL BE ALUMINUM ALLOY 6063-T5.
 - 2) INSTALLATION ANCHORS, #8 SCREWS, MUST BE SPACED 6" MAX. FROM CORNERS AND SPACED 18" O.C. MAX.
 - 3) FASTENERS SHALL BE 18-8 STAINLESS STEEL.
 - 4) WINDOW VENTS SHALL BE REMOVED WHEN WINDS EXCEED 75 MPH AS PER SECTION 2002.3.3 OF THE FLORIDA BUILDING CODE.
 - 5) AN APPROVED MEMBRANE OR MATERIAL SHALL BE PLACED BETWEEN ALL DISSIMILAR METALS TO CONTROL GALVANIC CORROSION.

WINDOW CRAFTSMEN, INC.
SARASOTA, FLORIDA

TITLE: ACRYLIC PICTURE WINDOW
WINDBREAK - INSTALLATION DETAILS,
IN ALUMINUM

ENGINEER: MARK A. SMITH	DRAWN BY: MAS	DATE: 11/20/07
DISCIPLINE: CIVIL	SCALE: N.T.S.	DWG. NO. WCI-PIC-001
FL. REG. NO.: 55511	REV. LETTER:	SHEET 1 OF 1

3738 KIINGSWOOD DR.
SARASOTA, FL 34232