

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI005904A-R4  
DATE: 12/10/2004  
CERTIFICATION PROGRAM: Structural  
COMPANY: Window Crafts.  
CODE: W-690-1  
REVISION DATE: 03/29/2016

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Window Craftsman</b> <b>6031 Clark Center Avenue</b> <b>Sarasota, FL 34238</b>	<b>Aluminum Fin Frame Double</b> <b>Hung Vinyl Wind Breaker</b> Configuration: XX Vinyl: 0.010" Thick  Frame:    W-4'6"            H-7'0" Panel:    W-3'6"            H-4'5"

SPECIFICATION	PRODUCT RATING
<b>ASTM E547-00/E330-99/02</b>	<b>Design Pressure: +9.6/-9.6 psf</b>

Product Tested By: Certified Testing Laboratories  
Report No: CTLA-1179W  
Expiration Date: **October 31, 2024**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'Shel' or similar, written over a horizontal line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122