

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI005980.01-R7  
DATE: 05/26/2007  
CERTIFICATION PROGRAM: Structural  
COMPANY: Window Crafts.  
CODE: 690-1  
REVISION DATE: 10/27/2020

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Window Craftsman</b> <b>6031 Clark Center Avenue</b> <b>Sarasota, FL 34238</b>	<b>Series "70R Glass Sliding Doors"</b> <b>Pocket/By-Pass/Center Meet</b> <b>Aluminum Sliding Impact Glass Door</b>  Configuration: XXXX Glazing-All Panels: 1/4" Heat Strengthened Glass/0.090" PVB/1/4" Heat Strengthened Glass  Frame: W-4876mm(192") H-2438mm(96") Panel: W-1283mm(50.5") H-2407mm(90.5")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> <b>TAS 201/202/203-94</b> <b>ASTM E1886-02/13a/E1996-02/14a</b>	<b>Class CW-PG70 4876 x 2438 (192 x 96)-SD</b> <b>SD-C70 4876 x 2438 (192 x 96)</b> <b>Design Pressure: +70/-70 psf</b> <b>Large Missile Impact Rated</b> <b>Wind Zone 3-Missile Level D</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3220-1D/210-3112-1/210-3112-1A/W-1855/W-1965  
Expiration Date: **February 28, 2025**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122