

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006062-R5
DATE: 06/07/2005
CERTIFICATION PROGRAM: Structural
COMPANY: Window Crafts.
CODE: 690-1
REVISION DATE: 10/27/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Window Craftsman 6031 Clark Center Avenue Sarasota, FL 34238	Series "45R Aluminum Picture Window" Aluminum Fin Frame Fixed Window Configuration: O Glazing: Monolithic (Annealed) Frame: W-1525mm(60") H-1525mm(60") DLO: W-1473mm(58") H-1473mm(58")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/NWWDA 101/I.S.2-97	Class CW-PG45 1525 x 1525 (60 x 60)-FW F-C45 Design Pressure: +45/-45 psf

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3160-02/W-1965
Expiration Date: November 30, 2028

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122