

# NOTICE OF PRODUCT CERTIFICATION




CERTIFICATION NO: NI006690-R6  
DATE: 08/29/2005  
CERTIFICATION PROGRAM: Structural  
COMPANY: Window Crafts.  
CODE: 690-1  
REVISION DATE: 10/27/2020

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Window Craftsman</b> <b>6031 Clark Center Avenue</b> <b>Sarasota, FL 34238</b>	<b>Series "50R Glass Sliding Doors"</b> <b>Aluminum Sliding Pocket By-Pass/ Center-Meet Glass Door</b> Configuration: XXXX Glazing: Monolithic (Tempered) Frame: W-4876mm(192") H-2438mm(96") Panel: W-1283mm(50.5") H-2407mm(90.5")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> <b>AAMA/NWDA 101/I.S.2-97</b> <b>TAS 202-94</b>	<b>Class CW-PG50 4876 x 2438 (192 x 96)-SD</b> <b>SD-C50 4876 x 2438 (192 x 96)</b> <b>SGD-C50</b> <b>Design Pressure: +50/-50 psf</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3220-1/1B/W-1965  
Expiration Date: **February 28, 2025**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122