

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI008056-R8
DATE: 05/26/2007
CERTIFICATION PROGRAM: Structural
COMPANY: Window Crafts.
CODE: 690-1
REVISION DATE: 10/27/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Window Craftsman 6031 Clark Center Avenue Sarasota, FL 34238	Series "50R Glass Sliding Doors" Pocket/By-Pass/Center Meet Aluminum Sliding Impact Glass Door Configuration: XXXX Glazing-All Panels: 1/4" Heat Strengthened Glass/0.090" PVB Interlayer by Solutia 1/4" Heat Strengthened Glass Frame: W-4876mm(192") H-2438mm(96") Panel: W-1283mm(50.5") H-2407mm(90.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 TAS 201/202/203-94 ASTM E1886-02/13a/E1996-02/14a	Class CW-PG50 4876 x 2438 (192 x 96)-SD SD-C50 4876 x 2438 (192 x 96) Design Pressure: +50/-50 psf Large Missile Impact Rated Wind Zone 4-Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3220-1C/210-3112-1/210-3112-1A/W-1855/W-1965
Expiration Date: **February 28, 2025**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122