

# NOTICE OF PRODUCT CERTIFICATION




CERTIFICATION NO: NI009413-R6  
DATE: 03/28/2008  
CERTIFICATION PROGRAM: Structural  
COMPANY: Window Crafts.  
CODE: 690-1  
REVISION DATE: 10/27/2020

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Window Craftsman</b> <b>6031 Clark Center Avenue</b> <b>Sarasota, FL 34238</b>	<b>"60R Aluminum Impact Picture Window"</b>  <b>Aluminum Fixed Window</b>  Configuration: O  Glazing: Laminate- 1/4" Heat Strengthened Glass/0.090" PVB by Solutia/1/4" Heat Strengthened Glass  Frame: W-1219mm(48")      H-3456mm(72") DLO: W-1168mm(46")      H-1778mm(70")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> <b>ASTM E1886-02/13a/E1996-02/14a</b> <b>TAS201/202/203-94</b>	<b>Class R-PG60 1219 x 3456 (48 x 72)-FW</b> <b>FW-R60 1219 x 3456 (48 x 72)</b> <b>Wind Zone 3-Missile Level D</b> <b>Design Pressure: +60/-60 psf</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3403-1 & 1A/W-1855/W-1965  
Expiration Date: November 30, 2028

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122